



**Informal Interpretation Report
Number 9507**



Date March 16, 2026

Edition 2023

Section 1009.3

Question:

Is it the intent of Section 1009.3 of the Accessibility volume of the Florida Building code family to limit the water depth of a pool having a sloped entry to 30" maximum depth?

Answer

No

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.