



**Informal Interpretation Report
Number 9509**



Date March 27, 2026

Edition 2023

Section 1010.1.7

Question:

Does 1010.1.7 apply to doors within nonaccessible hotel rooms?

Answer

Yes, if the occupancy is R-1, transient (not more than 30 days) such as a hotel. An R-2 non- transient hotel would not need to comply, per 1010.1.7 exception 3.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.