



**Informal Interpretation Report
Number 9568**



Date August 14, 2026

Edition 2023

Section R4501.17.1.9 (3)

Question:

Is it the intent of code to include Cameras advertised for the purpose to cover the Parentheses (3) if it carries the ASTM F2208 Certification to satisfy the Accidental entry or "In-Pool Alarm" feature?

Answer

If it meets the ASTM F2208 and complies with the requirements of the section of the code for protection, then it may be permissible. Manufacturer instructions would need to be available for plan review and inspection.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.