Informal Interpretation Report
Number 9588

Date October 23, 2026

Edition 2023

Section 403

Question:

Is it the intent of Section 403 to require compliance for minimum facilities in a new product delivery drone port in a parking lot?

Answer

Yes. If staff will be present, facilities are required.

Commentary:

None.

Notice:
The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.