Informal Interpretation Report
Number 9589

Date October 23, 2026

Edition 2023

Section 424.2

Question:

Is it the intent of Section 424.2 to apply to urinals that are provided in addition to, and are not substituted for, the water closets required by Table 403.1 — such that a separate toilet room containing only urinals and a lavatory is prohibited even where the required water closets are fully provided elsewhere without counting any urinal?

Answer

Yes

Commentary:

None.

Notice:
The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.