Informal Interpretation Report
Number 9594

Date October 23, 2026

Edition 2023

Section 1510.2

Question:

Are Rooftop Refrigeration/Electrical Penthouses exempt from the requirements of 61 - DEPARTMENT OF BUSINESS AND PROFESSIONAL REGULATION: Chapter 61-41 - MANUFACTURED BUILDINGS?

Answer

No. The answer may change if more specific information is provided

Commentary:

None.

Notice:
The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.